

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3225-0935:100

Page 1 of 1

**CATEGORY:** Fire Dampers

**LISTEE:** Nailor Industries, 4714 Winfield Rd, Houston TX 77039  
Contact: John Young (281) 590-1172 FAX (281) 590-3086

**PRODUCT:** Models 01, 02, 03, 05, \*FD, and \*FD3 series fire dampers. \*Models may be followed by additional suffix numbers or letters. \*All dampers are of the curtain blade type construction for vertical and horizontal installation. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** \*1½ hours - Models 01, 02, 03, FD  
\*3 hours - Models 05, FD3

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, fire rating, and UL label.

**APPROVAL:** Listed as fire dampers rated for 1½ or 3 hours for use in HVAC duct systems passing through fire resistive walls and partitions. Refer to listee's Installation Instruction Manual for details.

**NOTE:** Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage dampers.

\*Rev. 05-10-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager